



Ei450 RadioLINK Alarm Controller

TEST by holding the button until the segment lights up blue. Release once all alarms are sounding - they will stop sounding shortly.

If the system is activated and the source is not obvious, see which indicator is illuminated on the switch.

If carbon monoxide (**CO**) is showing, open doors and windows while evacuating the premises and contact the appropriate authorities.

If **FIRE** is showing but there is no fire, press the button.

The **LOCATE** segments will change from red to blue. Shortly, all alarms will stop sounding except the source alarm(s).

If you are satisfied there is no fire but the smoke/heat alarm is still sounding, wait until the **SILENCE** segment is flashing red, then press the button. The segment will turn blue, and after a delay the alarm(s) will stop sounding.

All segments on the controller will flash **green** momentarily to indicate that the alarm controller is back in standby.

